

F.A.O. Gillian Pearce  
Met Police  
[Gillian.D.Pearce@met.police.uk](mailto:Gillian.D.Pearce@met.police.uk)

Date 14 December 2023  
Our Ref 90/002037  
Your Ref

Dear Madam,

**Premises: Oliver's Food 4 Life, 12 Brockley Cross, Brockley, SE4 1BE.**

The London Fire Commissioner (the Commissioner) is the fire and rescue authority for London. The Commissioner is responsible for enforcing the Regulatory Reform (Fire Safety) Order 2005 (as amended) (The Order) in London.

With reference to your email dated 14<sup>th</sup> November 2022, in respect of the above-mentioned premises has been examined and I am **not** satisfied with the proposals in relation to the fire precautionary arrangements. This is mainly because there has been no Fire Risk Assessment carried out and there is a lack of fire safety provisions, including detection and warning within the premises.

A Fire Safety Advisor recently visited and told them to get a Fire Risk Assessment carried out by a competent person. They will then carry out a full fire safety inspection.

This is without prejudice to any requirements or recommendations that may be made by the Commissioner under the Regulatory Reform (Fire Safety) Order 2005 (as amended)/Petroleum (Consolidation) Act 1928, the local authority or the Health and Safety Executive.

Any queries regarding this letter should be addressed to the person named below. If you are dissatisfied in any way with the response given, please ask to speak to the Team Leader quoting our reference.

Yours faithfully,

**for Assistant Commissioner (Fire Safety)**

Directorate of Operations  
FSR-AdminSupport@london-fire.gov.uk

Reply to Donna Trelvellick  
E-mail donna.trelvellick@london-fire.gov.uk  
Direct T 07748 110929

**The London Fire Brigade promotes the installation of sprinkler suppression systems, as there is clear evidence that they are effective in suppressing and extinguishing fires; they can help reduce the numbers of deaths and injuries from fire, and the risk to firefighters.**