

BMI Healthcare
c/o Kieren Stagg at Kendall Kingscott Ltd
Glentworth Court
Lime Kiln Close
Stoke Gifford
BS34 8SR

Date: 11th April 2022
Reference: R9080-2 Rev 0

Dear Kieren

RE: Blackheath Hospital – Response to Comments (Planning Reference DC/21/123944)

Further to recent correspondence, we have been asked to comment on noise from an existing MRI chiller in relation to planning application reference DC/21/123944 for new services plant at Blackheath BMI Hospital.

24 Acoustics is confident that noise from the existing MRI chiller on the east façade of the hospital did not affect the measured background noise levels during the survey described in 24 Acoustics' plant noise assessment (report reference R9080-1 Rev 1). The existing chiller is approximately 70 metres from the measurement location and acoustically screened by the central two storey hospital building and the original three storey hospital building.

I trust the above is in order.


Yours sincerely,
For 24 Acoustics Ltd

Neil McLeod BA(Hons) MIOA
Senior Consultant



Measurement Location

Existing MRI Chiller

Project: Blackheath Hospital Reception		Title: Aerial view and location of survey and existing chiller		
DWG No: Figure 1	Scale: N.T.S.	Rev: -		
Date: April 2022	Drawn By: NM	Job No: 9080		